



കേന്ദ്രീയ വിദ്യാലയം നം 1, പാലക്കാട്
 केन्द्रीय विद्यालय नं.1 पालक्काड
 KENDRIYA VIDYALAYA NO.1, PALAKKAD
 कार्यालय/Office : 0491-2555316
 E-mail : principal*327@yahoo.co.in
 वेबसाइट /Website : www.kv1palakkad.nic.in
 Address : Hemambika Nagar, Palakkad Dt,Kerala-678 009



Date: 06.06.2022

F. 3-1/ KVP/2022-23/57

उपायुक्त
 The Deputy Commissioner,
 केन्द्रीय विद्यालय संगठन
 Kendriya Vidyalaya Sangathan,
 क्षेत्रीय कार्यालय
 Regional Office,
 एरणकुलम ,ERNAKULAM

विषय/Sub: अग्निशमन उपकरण और टाइल कार्य हेतु छोटे निर्माण के तहत जमा कार्य की अनुमति- संबंधित/
 Permission for deposit work under petty construction for Fire Fighting Equipment and Tile works -reg.

- संदर्भ/Ref :-
1. KV RO (EKM). No.F.310112/2020-21/KVS RO (EKM)/1PKD, date: 12/11/2021
 2. Our Lr. No. F. 3-1/KVP/2021-22/559 Dt. 28/12/2021
 3. CPWD Lr. No. C-1086/2022 date: 21/03/2022.

महोदय/Sir,

With reference to letter cited above, it is informed that we have not yet received the permission from KVS for the following deposit works under petty construction:

1. Firefighting Equipment estimate for Rs.14,25,480/-
2. Tile work for class rooms Rs.7,33,300/-

We have approached the District Fire Safety Department for issue of the Fire Safety Certificate, for submitting to CBSE for renewal of Affiliation which is expiring in 31st March 2024, but the Fire Department is not issuing the Certificate in absence of installation of Fire Protection System. The letter received from the District Fire Offices is enclosed for your reference (Ref: No.C-1086/2022 of date: 21/03/2022)

Installation of Fire Fighting Equipment amounting to Rs.14,25,480/- (approx) provided by CPWD was forwarded to KV RO (EKM) vide letter no.3-1/KVP/2021-22/559, dt-28/12/2021 which was further sent to KVS (HQ) by RO vide their letter no. F.310112/2020-21/KVS RO (EKM)/1PKD, date: 12/11/2021 (copy enclosed)

KVS(HQ) clarification to the same were also cleared vide our letter no.3-1/KVP/2021-22/559, date:28/12/2021.

It is mentioned that the prices of Equipment's are increasing day by day. If there is a delay in sanction of the installing Fire Fighting Equipment, the price may further increase and in that case we have to ask for further estimates from CPWD.

It is therefore requested to grant sanction for installation of Fire Fighting Equipments, so that we are able to apply for extension of CBSE Affiliation on time.

धन्यवाद /Thanking you,

भवदीय/Yours faithfully,

PIK
 (प्यारा लाल/PIARA LAL) PRINCIPAL
 प्राचार्य/PRINCIPAL (I/C) KVS Vidyalaya No:1
 हेमाम्बिका नगर / Hemambika Nagar
 678 009 Palakkad-678009

PK



सत्यमेव जयते

GOVERNMENT OF INDIA
CENTRAL PUBLIC WORKS DEPARTMENT
OFFICE OF THE ASSISTANT ENGINEER (E),
TRICHUR CENTRAL ELECTRICAL SUB-DIVISION,
4TH FLOOR, AG'S OFFICE BUILDING, K.N.ROAD,
THRISSUR-680 020.



Tele & Fax No.0487 -2331337	E-mail:acpwdtsr@gmail.com	Website: www.cpwdsr.tn.nic.in
No.23 (4(A)) /TCESD/2023/120		Date. 06.05.2023

To

The Executive Engineer (E) - Kochi
CPWD, 4th Floor,
Kendriya Bhavan,
Kakkanad,
Kochi-682037

Sir,

Sub: Providing Fire Hydrant system in Kendriya Vidyalaya No.1, Palakkad. - Reg.

Ref: Letter No. F.3-1/KVP/2023-24/16 dated 01-05-2023 of the Principal, KV No.1, Palakkad

The undersigned along with Assistant Engineer (Civil), CPWD, Thrissur visited the site on 02-05-2023 for ascertaining the existing infrastructure for preparation of revised PE for "providing fire hydrant system". It is observed that, the RCC OH tank of 15000Ltr capacity is provided in the main school building and 2 Nos 1000Ltr capacity PVC OH tank in the new building. There is no scope for installation of 10000Ltr capacity metallic / RCC tank in the new building. However, the new block is attached / butted to the main school building and interconnected with corridors. Hence, the entire building can be treated as one building for providing fire hydrant system.

Since the inspection report No. DFOPKD/367/2023-C doesn't clarify any specific requirements and confusing, it is recommended to obtain NOC from the department of fire and rescue services, Kerala by the KV Palakkad authorities. Accordingly, the combined revised PE (both civil and electrical portion) can be prepared and submitted as per terms and conditions of the fire NOC.

Yours faithfully,

sd/-
Assistant Engineer (E)
TCESD, CPWD, Thrissur

Copy to:

1. The Principal, Kendriya Vidyalaya No.1, Palakkad for information and necessary action please.
2. The Executive Engineer - Thrissur, CPWD, Thrissur for information and necessary action please.

R
Assistant Engineer (E)
TCESD, CPWD, Thrissur

*To office to
get - noc from
fire dept.
8/5/23*

ഭരണഭാഷ-മാതൃഭാഷ



DFOPKD/367/2023-C

ജില്ലാ ഫയർ ഓഫീസറുടെ കാര്യാലയം
ഫയർ ആന്റ് റെസ്ക്യൂ സർവ്വീസസ്
പാലക്കാട്. തീയതി 20.03.2023.
Phone No.0491 2505702
E mail : adopkd.frs@kerala.gov.in

ജില്ലാ ഫയർ ഓഫീസർ
ഫയർ ആന്റ് റെസ്ക്യൂ സർവ്വീസസ്
പാലക്കാട്.

പ്രിൻസിപ്പാൾ
കേന്ദ്രീയ വിദ്യാലയം നം.1
ഹേമാംബിക നഗർ
പാലക്കാട് - 678 009.

സർ,

വിഷയം :- ഫയർ ആന്റ് റെസ്ക്യൂ സർവ്വീസസ്, ജില്ലാ ഫയർ ഓഫീസ്, പാലക്കാട് - കേന്ദ്രീയ വിദ്യാലയത്തിന് NOC അനുവദിക്കുന്നതിനുള്ള അപേക്ഷ സംബന്ധിച്ച്.

- സൂചന :-
1. താങ്കളുടെ 10.02.2023-ലെ അപേക്ഷ നം. F.3-1/KVP/2022-23/276.
 2. പാലക്കാട് സ്റ്റേഷൻ ഓഫീസറുടെ 03.03.2023-ലെ കത്ത് നം.159/2023.

സൂചന (1) പ്രകാരമുള്ള അപേക്ഷ പ്രകാരം നടപടികൾ സ്വീകരിക്കുന്നതിന്റെ ഭാഗമായി കെട്ടിടം പരിശോധിച്ച് റിപ്പോർട്ട് സമർപ്പിക്കുന്നതിന് പാലക്കാട് സ്റ്റേഷൻ ഓഫീസർക്ക് നിർദ്ദേശം നൽകിയതിന്റെ അടിസ്ഥാനത്തിൽ, പരിശോധന നടത്തി സൂചന (2) പ്രകാരം റിപ്പോർട്ട് സമർപ്പിച്ചിരുന്നു. ടി റിപ്പോർട്ട് പരിശോധിച്ചതിൽ നിന്നും, താഴെപ്പറയുന്ന സുരക്ഷാ ക്രമീകരണങ്ങൾ ഏർപ്പെടുത്തേണ്ടതാണെന്ന് കാണുന്നു.

പ്രധാന കെട്ടിടത്തിന് 2 സ്റ്റേയർ കേസുകൾ നിർബന്ധമായും ഒരുക്കിയിരിക്കേണ്ടതാണ്. കൂടാതെ പുതിയതായി നിർമ്മിച്ച കെട്ടിടത്തിനും 2 സ്റ്റേയർ കേസുകൾ സജ്ജീകരിക്കേണ്ടതാണ്.

രണ്ട് കെട്ടിടങ്ങളും തമ്മിൽ യോജിപ്പിച്ചിട്ടുള്ളതിനാൽ രണ്ട് കെട്ടിടങ്ങളിലും KMBR-2019-NBC-2016 Part IV Fire & Life Safety യിൽ നിഷ്കർഷിച്ചിട്ടുള്ള പ്രകാരം അഗ്നിപ്രതിരോധ സംവിധാനം (Fire Protection System) ഏർപ്പെടുത്തിയതിനുശേഷം, നിശ്ചിത പരിശോധനാഫീസ് ചലാൻ മുഖേന അടച്ച് രശീതും, സിവിൽ പ്ലാൻ, ഫയർ സിസ്റ്റം പ്ലാൻ, ചെക്ക് ലിസ്റ്റ് എന്നിവ സഹിതം ഓൺലൈൻ ആയും, പാലക്കാട് സ്റ്റേഷൻ ഓഫീസർ മുഖേന രേഖാമൂലവും അപേക്ഷ സമർപ്പിക്കേണ്ടതാണെന്ന് ഇതിനാൽ അറിയിക്കുന്നു.

3
25/3/23

Mr. Rayan
9497750069

വിശ്വസ്തയോടെ

ജില്ലാ ഫയർ ഓഫീസർ
ഫയർ ആന്റ് റെസ്ക്യൂ സർവ്വീസസ്
പാലക്കാട്